

消防處
牌照及審批總區
通風系統課
香港新界葵涌興盛路86號消防處
葵涌辦公大樓3字樓



**FIRE SERVICES DEPARTMENT
LICENSING & CERTIFICATION COMMAND**

Ventilation Division

3/F, Fire Services Department Kwai Chung Office Building,
No. 86 Hing Shing Road, Kwai Chung,
New Territories

本處檔號 Our Ref.: FP(LC) 317/21
來函檔號 Your Ref.: JLY-BS8592-01 &
HC-LT--BS8592-001
圖文傳真 Fax: 2367 3206
電話 Tel. No.: 3961 5299

20 August 2021

Hilly Cables Ltd.
Block A 12/F Room 4
Po Yip Building
62-70 Texaco Road
Tsuen Wan
Hong Kong

(Attn: Mr. T.K. CHEUNG)

Dear Sir,

“Jinlongyu” BS 8592:2016 Single Core Electric Cables

I refer to your above letters dated 21.6.2021 and 10.8.2021 respectively together with your product catalogue, a set of test reports, quality management certificate, certificate of product approval and the revised application form signed on 9.8.2021 with respect to the captioned products.

We have no objection in principle to the use of “Jinlongyu” BS 8592:2016 single core electric cables for the fire services installations in Hong Kong subject to compliance with the Codes of Practice for Minimum Fire Service Installations and Equipment and Inspection, Testing and Maintenance of Installations and Equipment, 2012 Edition, relevant FSD Circular Letters and according to the following details:

Supplier	:	Hilly Cables Ltd
Manufacturer	:	Huizhou Jinlongyu Cable Industrial Development Co., Ltd PRC
Model	:	BS 8592:2016 Single Core Fire Resistant Cables
Construction	:	Mica/ Glass Tape, Low Smoke Zero (LSOH) insulated single-core cable

/2...

- Conductor Size : Single cores 1.5 mm² to 70mm²
- Test Certificate/
Report : a) Certificate No. 202/002/007 Issue No.4 of
25.5.2021 issued by BASEC;
b) Test reports issued by BASEC
P1TTF2221 of 20.5.2021.
- Test Standard &
Result : a) BS 6387:2013, Category C, W, Z (for cables
with overall diameter not exceeding 20mm)
- Quality
Assurance
Scheme : The manufacturer operates a quality management
system conforms to: -
ISO 9001:2015 certified by BASEC under
Certificate No. CS1-246/002 Issue no:1 of 5.2.2020
(until 9.4.2023)
- Remark : a) Valid certificates and test reports shall be
maintained;
b) The cables shall bear appropriate markings of the
certification body for identification purpose; and
c) This assessment is subject to review by April
2026.

Yours faithfully,



(Stanley CHOW)
for Director of Fire Services

c.c. Mr. Vito YAO- Jinlongyu Group Co., Ltd.
Jinlongyu Industrial Zone,
288 Jihua Road,
Jihua Street, Longgang District
Shenzhen, Guangdong, 518112, China

SC/cfl

FileCode: JLY BS 8592 cables 20210820.doc