

+852 2367 3206

消防處  
牌照及審批總區  
通風系統課  
香港新界葵涌興盛路86號消防處  
葵涌辦公大樓3字樓



FIRE SERVICES DEPARTMENT  
LICENSING & CERTIFICATION COMMAND  
Ventilation Division  
3/F, Fire Services Department Kwai Chung Office Building,  
No. 86 Hing Shing Road, Kwai Chung,  
New Territories

本處檔號 Our Ref.: FP(LC) 317/21  
來函檔號 Your Ref.: JLY-BS 7846-03 and  
JLY-BS 7846-04  
圖文傳真 Fax: 2367 3206  
電話 Tel. No.: 3961 5299

28 December 2020

JLY Group Co., Ltd.  
Jinlongyu Industrial Zone,  
288 Jihua Road,  
Jihua Street, Longgang District  
Shenzhen  
Guangdong,  
China

(Attn: Mr. Anthony ZHOU/ Mr. CHEUNG)

Dear Sir,

**"JLY" BS 7846 F2 Armoured Fire Cables**

I refer to your letter without date which was received by this Department on 4.5.2020 enclosing a set of test reports, your supplementary letter ref. JLY-BS7846-01 dated 17.7.2020, your letter ref. JLY-BS7846-02 dated 10.8.2020, your letter ref. JLY-BS7846-03 dated 22.9.2020 and your letter ref. JLY-BS7846-04 dated 24.11.2020 (regarding change of cable range) with respect to the captioned products.

We have no objection in principle to the use of "JLY" BS 7846 F2 armoured fire cables for the fire services installations in Hong Kong subject to compliance with the Codes of Practice for Minimum Fire Service Installations and Equipment and Inspection, Testing and Maintenance of Installations and Equipment, 2012 Edition, relevant FSD Circular Letters and according to the following details:

Supplier	:	Hilly Cables Ltd
Manufacturer	:	Huizhou Jinlongyu Cable Industrial Development Co., Ltd PRC
Model	:	BS 7846 F2 Armoured Fire Cables
Construction	:	Mica/ Glass Tape, Low Smoke Zero (LSOH) XLPE insulated sheathed multi-core armoured cable

/2...

+852 2367 3206

—2—

- Conductor Size : 2 cores to 4 cores 1.5 mm<sup>2</sup> to 400mm<sup>2</sup>
- Test Certificate/  
Report : Certificate No. 202/002/006 Issue No.4 of 9.4.2020  
issued by BASEC;  
Test reports issued by BASEC  
a) M1TTF2221 of 23.10.2019; and  
b) M3TTF2221 of 28.11.2019
- Test Standard &  
Result : a) BS 7846:2015 Category F2;  
b) BS 6387:2013, Category C, W, Z (for cables  
with overall diameter not exceeding 20mm);  
c) BS 6387:2013, Category C, W, Z and additional  
provisions given in Annex I of BS 7846: 2015 (for  
cables with overall diameter exceeding 20mm)
- Quality  
Assurance  
Scheme : The manufacturer operates a quality management  
system conforms to  
a) BS EN ISO 9001:2015 certified by BASEC under  
Certificate No. CS1-246/002 of 5.2.2020 (valid  
until 9.4.2023)
- Remark : a) Valid certificates and test reports shall be  
maintained;  
b) The cables shall bear appropriate markings of the  
certification body for identification purpose; and  
c) This assessment is subject to review by October  
2025.

This letter **supersedes** my previous letter dated 4.12.2020. Should you have any questions on the above, please contact Mr. Edwin LEUNG at 3961 5288.

Yours faithfully,



(Stanley CHOW)  
for Director of Fire Services

c.c. Hilly Cables Ltd (Mr. CHEUNG), Fax. 26539292

Internal

Engr(FSI)3

CTO(Vent) – Fax: 2382 2495

SC/cfl

FileCode: Engrfsi3 JLY bs7846 F2 armoured cables 2020/2028.doc