

消防處  
牌照及審批總區  
消防工程合規課  
通風系統組  
香港灣仔告士打道五號  
稅務大樓三十五樓



FIRE SERVICES DEPARTMENT  
LICENSING & CERTIFICATION COMMAND  
Fire Protection Engineering Compliance Division  
Ventilating Systems Group  
35/F, Revenue Tower,  
5 Gloucester Road, Wan Chai, Hong Kong

本處檔號 Our Ref.: FSD LC VSG 317/21  
來函檔號 Your Ref.:  
圖文傳真 Fax: (852) 2382 2495  
電話 Tel. No.: (852) 2718 7567  
電郵 E-mail: fsvent@hkfsd.gov.hk

8 November 2023

Hilly Cables Ltd.  
Block A 7/F Room 3  
Po Yip Building  
62-70 Texaco Road  
Tsuen Wan, Hong Kong

(Attn: Mr. T.K. CHEUNG)

Dear Sir,

**“Hilly” or “Jinlongyu Group Co., Ltd ” BS 7846:2015**  
**Armoured Fire Resisting Cables F120**

I refer to your application form signed on 21.8.2023 enclosing manufacturer's letter, a set of test reports, certificates and product catalogue which was received by this Department on 21.8.2023 with respect to the captioned product for our acceptance assessment.

According to FSD Circular Letter no. 3/2020, any fire service installation / equipment (except portable equipment, i.e. fire extinguisher, fire blanket, etc.) which is certified and properly listed by one of our recognized Product Certification Bodies (PCBs) is deemed to be accepted by this Department subject to (i) no change of the listing condition; and (ii) such equipment and the installation being in conformity with all relevant local requirements.

The application for the captioned product assessment by this Department is not necessary subject to their valid BASEC listing in compliance with current version of BS 7846:2015 (Cat. F120) as listed in the BASEC Certificate and their correct cable markings.

Yours faithfully,

(CHAN Wai-lam)  
for Director of Fire Services

Internal  
Engr(FPF)3  
CTO(FPEC) -- Fax: 2382 2495

SC/cfl

FileCode: Hilly\_JLY BS7846-F120 armoured fire resisting cables\_20231108 (listed).doc